









<u>NEW</u>	<u>EXISTING</u>	<u>DESCRIPTION</u>
		RIGHT-OF-WAY
		PROPERTY LINE
		CENTERLINE
		WATERLINE
		GATE VALVE
		FIRE HYDRANT



8. Curb and gutter exists on the south side of Towner Avenue from the west boundary of Lot 38 west for approximately 100 feet. Remove 4' of the existing sidewalk and curb and gutter to install hydrant in line with property line. Then replace curb and gutter and sidewalk to a point 4' east of property line for protection of the hydrant.

APPROVALS	ENGINEER	DATE	APPROVALS	ENGINEER	DATE
City Engineer	<i>[Signature]</i>	11/5/85	Liquid Waste	<i>[Signature]</i>	9/18/85
A C E Design	<i>[Signature]</i>	11/18/85	Traffic	<i>[Signature]</i>	9/18/85
ACE Hydrology	<i>[Signature]</i>	9/18/85	Water	<i>[Signature]</i>	9/18/85

DRAWING NO.	2598	MAP NO.	H-15	SHEET	OF	1	1
----------------	------	---------	------	-------	----	---	---

26 25980186