



<p style="text-align: center;"><b>LOCATION MAP</b>      <b>ZONE ATLAS E-11</b></p>		<b>AS BUILT INFORMATION</b> AUTH. BY: JAMES INDUST. DATE: STORED IN: JUNE 5, 1987 ACCESSIBLE BY: M. NEPHEW DATE: 7/31/87 FIELD LOCATION BY: [blank] DATE: [blank] DRAWINGS CORRECTED BY: ENL <b>MICRO-FILM INFORMATION</b> RECORDED BY: NO DATE: [blank]	
<b>NOTICE TO CONTRACTORS</b>		<b>BENCH MARKS</b> BM 5-EIL A Square, LT. Chisled On Top Of Curb At The NW Corner Return Located At The Intersection Of Montano Rd And Vaile Vista Dr Elevation 5506.57	
<ol style="list-style-type: none"> <li>1. All work detailed on these plans to be performed under contract shall, except as otherwise stated, provided for herein, be constructed in accordance with the City of Albuquerque Interim Standard Specifications for Construction 1985.</li> <li>2. Two (2) working days prior to any excavation, the contractor must contact Line Locating Service, 765-1234, for location of existing utilities.</li> <li>3. Prior to construction, the contractor shall excavate and verify the horizontal and vertical locations of all obstructions. Should a conflict exist, the contractor shall notify the engineer or surveyor so that the conflict can be resolved with minimum amount of delay.</li> </ol>		<b>SURVEY INFORMATION</b> FIELD NOTES BY: G. Archande NO.: 20-59 DATE: 2-17-87	
<b>THE FOLLOWING NOTES ALSO APPLY WHEN CHECKED</b>		<b>ENGINEER'S SEAL</b> [Seal Area]	
<input checked="" type="checkbox"/> All utilities and utility service lines shall be installed prior to paving. <input checked="" type="checkbox"/> Backfill compaction shall be according to specified street use. <input type="checkbox"/> Tack coat requirements shall be determined by the City Engineer. <input type="checkbox"/> Sidewalks and wheelchair ramps within the curb returns shall be constructed wherever a new curb return is constructed. <input type="checkbox"/> If curb is depressed for a driveway or a handicap ramp, the driveway or ramp shall be constructed prior to acceptance of the curb and gutter. <input type="checkbox"/> All storm drainage facilities shall be completed prior to final acceptance.		<b>KEYED NOTES:</b> ① BACKFILL AND COMPACTION (90% MAXIMUM DENSITY) SHOULD ASSURE A MINIMUM COVER OF 3.5 FEET FOR THE WATER LINE IMMEDIATELY AFTER INSTALLATION, AND A MAXIMUM COVER OF 5 FEET UNDER FINISHED STREET MADE CONDITIONS. ② INSTALL 8"x4" TEE AND SERVICE STUB OUT FOR FUTURE SANITARY SEWER SERVICE CONNECTION (SAS-C). SEE CITY'S STANDARD SPECIFICATIONS AND DRAWINGS FOR DETAILS. ③ OBSERVE MINIMUM HORIZONTAL DISTANCE REQUIREMENTS OF 10 FEET BETWEEN CENTER LINES OF SAS AND WATERMAIN. AT ALL PLACES THROUGH THE INSTALLATION.	
<b>LEGEND</b> Rem & Repl. Residential Pavement		<b>REVISIONS</b> DESIGN DESIGNED BY: P.G. DATE: Mar., 1987 DRAWN BY: A.J.O. Sr. DATE: Mar., 1987 CHECKED BY: P.G. DATE: Mar., 1987	
 Russell B. Smith 9-29-82			
 Heather W. Anderson			
<b>CITY OF ALBUQUERQUE</b> <b>MUNICIPAL DEVELOPMENT DEPARTMENT</b> <b>ENGINEERING DIVISION</b>			
<b>TITLE: WATER AND SANITARY SEWER IMPROVEMENTS FOR AVENIDA CHIQUITA, DEBORAH AVE. AND AVENIDA ARTURO NW.</b>			
APPROVALS	ENGINEER	DATE	APPROVALS
City Engineer	[Signature]	4/11/87	Liquid Waste
A.C.E - Design	[Signature]	4-6-87	Traffic
A.C.E - Hydrology	[Signature]	4-6-87	Water
<b>DRAWING NO. 3158</b>		<b>MAP NO. E-II</b>	
<b>SHEET 1 OF 1</b>			