



- |  |   |
|--|---|
| <p>14. WATERLINES SHALL BE A MINIMUM COVER OF 3' UNLESS OTHERWISE NOTED.</p> <p>15. FIRE HYDRANTS SHALL BE INSTALLED IN ACCORDANCE WITH CITY STD. DWG. 2340.</p> <p>16. WATERLINE CONNECTIONS SHALL BE CONSTRUCTED IN ACCORDANCE WITH CITY STD. DWG. 2301.</p> <p>17. VALVE BOXES SHALL BE CONSTRUCTED IN ACCORDANCE WITH CITY STD. DWG. 2325 OR 2326.</p> <p>18. CONTRACTOR SHALL PROVIDE 12" SUB-GRADE PREPARATION UNDER ALL NEW PAVEMENT, CURBS AND GUTTERS, VALLEY GUTTERS AND CONCRETE FILLETS.</p> <p>19. WHEN ABUTTING NEW PAVEMENT TO EXISTING, CUT BACK EXISTING PAVEMENT TO A NEAT, STRAIGHT LINE AS REQUIRED TO REMOVE ANY BROKEN OR CRACKED PAVEMENT, AND MATCH NEW TO EXISTING.</p> | <p>LOCKED MECHANICAL JOINTS.</p> <p>12. ELECTRONIC MARKER DISCS SHALL BE PLACED IN ACCORDANCE WITH SECTION 170 OF THE CITY OF ALBUQUERQUE, STANDARD SPECIFICATIONS, PUBLIC WORKS CONSTRUCTION.</p> <p>13. WATERLINE 12" IN DIAMETER AND SMALLER MAY BE DUCTILE IRON OR PVC.</p> |
|--|---|

  

<p>CITY OF ALBUQUERQUE MUNICIPAL DEVELOPMENT DEPARTMENT ENGINEERING DIVISION</p>			
<p>TITLE: APPROX. 270' NW OF CONSTITUTION AVE &amp; INDIAN SCH. RD NE HIGH RIDGE SHOPPING CENTER 1 NEW FIRE HYDRANT</p>			
<p>APPROVALS</p> <p>City Engineer</p> <p>A-C-E Design</p> <p>A-C-E-Hydrology</p>	<p>ENGINEER</p> <p><i>[Signature]</i></p> <p><i>[Signature]</i></p> <p><i>[Signature]</i></p>	<p>DATE</p> <p>6/11/97</p> <p>5-27-97</p> <p>5-27-97</p>	<p>APPROVALS</p> <p>Liquid Waste</p> <p>Traffic</p> <p>Water</p>
		<p>ENGINEER</p> <p><i>[Signature]</i></p> <p>NADW H</p> <p><i>[Signature]</i></p>	
		<p>DATE</p> <p>5-27-97</p> <p>5-27-97</p> <p>5-27-97</p>	

  

<p>DRAWING NO.</p> <p style="font-size: 24pt; text-align: center;">3249</p>	<p>MAP NO.</p> <p style="font-size: 24pt; text-align: center;">J-22-Z</p>	<p>SHEET OF</p> <p style="font-size: 24pt; text-align: center;">1 1</p>
---	---	---