



VICINITY MAP
SCALE: 1" = 800'

GENERAL NOTES:

- ALL WORK DETAILED ON THESE PLANS TO BE PERFORMED UNDER CONTRACT SHALL, EXCEPT AS OTHERWISE STATED OR PROVIDED HEREON, BE CONSTRUCTED IN ACCORDANCE WITH THE CITY OF ALBUQUERQUE STANDARD SPECIFICATIONS - 1986.
- TWO (2) WORKING DAYS PRIOR TO ANY EXCAVATION, CONTRACTOR MUST CONTACT LINE LOCATING SERVICE, 765-1234, FOR LOCATION OF EXISTING UTILITIES.
- IF ANY UTILITY LINES, PIPELINES, OR UNDERGROUND UTILITY LINES ARE SHOWN ON THESE DRAWINGS, THEY ARE SHOWN IN AN APPROXIMATE MANNER ONLY, AND SUCH LINES MAY EXIST WHERE NONE ARE SHOWN. IF ANY SUCH EXISTING LINES ARE SHOWN, THE LOCATION IS BASED ON INFORMATION PROVIDED BY THE OWNER OF SAID UTILITY, AND THE INFORMATION MAY BE INCOMPLETE, OR MAY BE OBSOLETE BY THE TIME CONSTRUCTION COMMENCES. THE ENGINEER HAS UNDERTAKEN NO FIELD VERIFICATION OF THE LOCATION, DEPTH, SIZE, OR TYPE OF EXISTING UTILITY LINES, PIPELINES, OR UNDERGROUND UTILITY LINES. THEREFORE, THE CONTRACTOR SHALL INFORM ITSELF OF THE LOCATION OF ANY UTILITY LINE, PIPELINE, OR UNDERGROUND UTILITY LINE IN OR NEAR THE AREA OF THE WORK IN ADVANCE OF AND DURING EXCAVATION WORK. THE CONTRACTOR IS FULLY RESPONSIBLE FOR ANY AND ALL DAMAGE CAUSED BY ITS FAILURE TO LOCATE, IDENTIFY AND PRESERVE ANY AND ALL EXISTING UTILITIES, PIPELINES, AND UNDERGROUND UTILITY LINES. IN PLANNING AND CONDUCTING EXCAVATION, THE CONTRACTOR SHALL COMPLY WITH THE CITY OF ALBUQUERQUE STANDARD SPECIFICATIONS, RULES AND REGULATIONS, IF ANY, PERTAINING TO THE LOCATION OF THESE LINES AND FACILITIES.
- SHOULD A CONFLICT EXIST BETWEEN THESE PLANS AND ACTUAL FIELD CONDITIONS, THE CONTRACTOR SHALL PROMPTLY NOTIFY THE ENGINEER IN WRITING SO THAT THE CONFLICT CAN BE RESOLVED WITH A MINIMUM AMOUNT OF DELAY FOR ALL PARTIES.
- THE CONTRACTOR SHALL MAINTAIN ACCESS TO ADJACENT PROPERTIES DURING CONSTRUCTION.
- ALL WORK ON THIS PROJECT SHALL BE PERFORMED IN ACCORDANCE WITH APPLICABLE FEDERAL, STATE AND LOCAL LAWS, RULES AND REGULATIONS, CONCERNING SAFETY AND HEALTH.
- THE CONTRACTOR MUST SUBMIT A CONSTRUCTION SIGNING AND BARRICADING PLAN TO TRAFFIC ENGINEERING TO RECEIVE A BARRICADING PERMIT 48 HOURS PRIOR TO CONSTRUCTION.
- ALL UTILITIES AND UTILITY SERVICE LINES SHALL BE INSTALLED PRIOR TO PAVING.
- BACKFILL COMPACTION SHALL BE ACCORDING TO SPECIFIED STREET USE.

WATERLINE NOTES:

- ALL STATIONING IS BASED ON WATERLINE EASEMENT CENTERLINE UNLESS INDICATED OTHERWISE.
- THE CONTRACTOR SHALL FURNISH ELECTRONIC MARKER DISKS (END) ON ALL WATER SERVICE STUBS, CAPS AND PLUGS.
- WATER MAIN SHALL BE PVC C-900 PIPE OR AS APPROVED BY THE CITY OF ALBUQUERQUE WATER RESOURCES DIVISION.
- WATER LINE SHALL HAVE A MINIMUM COVER OF 4'0" (TOP OF ASPHALT PAVEMENT TO TOP OF PIPE).
- ALL PIPE SHALL BE FURNISHED WITH CLASS 'C' BEDDING UNLESS OTHERWISE NOTED. ALL TRENCH BACKFILL SHALL BE COMPACTED TO A MINIMUM OF 90% OF OPTIMUM, AS PER ASTM D 1557.
- WHERE SEWER AND WATER LINES CROSS, IF VERTICAL CLEARANCE DOES NOT EXCEED 1'6", THE SEWER LINE MUST BE PRESSURE PIPE, OR SHALL BE CONCRETE ENCASED 10" EACH SIDE OF WATER LINE.
- FIRE HYDRANTS SHALL BE CONSTRUCTED IN ACCORDANCE WITH CITY OF ALBUQUERQUE STANDARD DRAWING 2140.
- 3" METERED SERVICE LINE SHALL BE CONSTRUCTED BY CITY OF ALBUQUERQUE. CONTRACTOR SHALL COORDINATE INSTALLATION WITH CITY OF ALBUQUERQUE WATER UTILITY DEPARTMENT.
- CONTRACTOR SHALL REMOVE AND REPLACE EXISTING PAVING FOR CITY-WIDE PAVEMENT CUTS FOR ALL UTILITIES AS PER CITY OF ALBUQUERQUE STANDARD DRAWING 2465.
- VALVE BOXES SHALL BE CONSTRUCTED IN ACCORDANCE WITH CITY OF ALBUQUERQUE STANDARD DRAWING 2325.

AS BUILT INFORMATION

STATION 15 IS A STANDARD N.M.S.H.C. BARS TABLET.
STAMPED STA. N.M. 36-7-8. STATION 15 LOCATED IN THE CENTER OF MEDIAN ON SAN MATEO JUST NORTH OF THE INTERSECTION OF SAN MATEO BLVD. N.E. & CUTLER AVE. N.E.

ENGINEER'S SEAL
NEW MEXICO
REGISTERED ENGINEER
19847
J. MONTANA

REVISIONS

NO.	DATE	REMARKS	DESIGNED BY	DRAWN BY	CHECKED BY
1	9/15/88	Revised from as-built information	L.P.U.	S.G.H.	J.G.M.

DESIGNED BY L.P.U. **DATE** 9/87
DRAWN BY S.G.H. **DATE** 9/87
CHECKED BY J.G.M. **DATE** 9/87

CITY OF ALBUQUERQUE
PUBLIC WORKS DEPARTMENT
ENGINEERING GROUP

TITLE: NEW FUTURES SCHOOL WATERLINE EXTENSION
STA. 10+00 TO STA. 12+56.66

APPROVALS	ENGINEER	DATE	APPROVALS	ENGINEER	DATE
ORC Chair	[Signature]	10/6/87			
Trans. Dev	[Signature]	10/6/87			
Utility Dev	[Signature]	11/03/87			

DRAWING NO. 3371 **MAP NO.** H-18 **SHEET** 1 **OF** 1

APPROVAL OF AS BUILT DRAWINGS
CHIEF CONSTRUCTION ENGINEER
[Signature]
DATE 7-19-88

APPROVED FOR CONSTRUCTION
[Signature]
CITY ENGINEER
DATE

JOB NO. 870803

DATE 7-19-88

DATE 7-19-88