

South
2nd St

BNSF
RR

Southside Treatment
Plant Administration
Bldg

781

783

782

784

CIP
7375.91
As-built
SL pl ned
BOLF W/63"OD
HOBAS PIPE
9/04
B U Const
E J Smith
GW 1 sp III

130 72" RCP

S=0.0005

07-030-60

ZONE
P-13

Note: Existing Pipe
was 72" I.D. Corrugated
Metal Pipe And Not
RCP as per info As-builts

SOUTH 2ND ST. EMERGENCY
72" SAS SLIPLINE
737591