


Google Maps 899 8th St SW



Map data ©2021 Google 100 ft

Google Maps 899 8th St SW




Image capture: Apr 2019 © 2021 Google

Albuquerque, New Mexico



Street View



I made a sight visit and I believe that eliminating all header curb would be beneficial while still not allowing water onto the property. Back driveway pad would be 6' deep with approx 14% slope while maintaining a 5' ADA compliant walkway. As it sits, it's a 21% slope in 2' and both ramps are not ADA compliant. No survey needed.