

Spaulding Lighting • 701 Millennium Boulevard • Greenville, SC 29607 • Phone: 864-678-1000

© 2015 SPAULDING LIGHTING, All Rights Reserved • For more information visit our website: www.spauldinglighting.com • Printed in USA CL1S-SPEC 2/15

Spauling Lighting • 701 Millennium Boulevard • Greenville, Sc 29607 • Prione: 864-678-1000 Due to our continued efforts to improve our products, product specifications are subject to change without notice.


PERFORMANO	5K (5100K Nominal, 67 CRI)				4K (4000K NOMINAL, 70 CRI)					3K (3000K NOMINAL, 80 CRI)								
NUMBER OF LEDS	DRIVE Current (Milliamps)	SYSTEM WATTS	DISTRIBUTION TYPE	LUMENS	LPW*	В	U	G	LUMENS	LPW*	В	ا	G	LUMENS	LPW*	В	U	G
	(MIZZIMII O)	11.7.110	2	3053	80	1	1	1	3077	81	1	2	2	2438	64	1	2	2
		0mA 38w	3	3075	81	1	1	1	3099	82	1	1	1	2456	65	1	1	1
March 1	400 0		4	3113	82	1	1	1	3136	83	1	1	1	2486	65	1	1	1
16	700mA		5S	3457	91	2	0	0	3484	92	2	0	0	2761	73	2	0	0
			5M	3731	98	2	0	0	3454	91	2	0	1	2737	72	2	0	0
			5W	3166	83	3	1	1	3160	83	2	1	1	2725	72	2	1	1
			2	6527	86	2	1	2	6042	80	2	1	2	4788	63	1	1	2
	700	70	3	6574	87	2	1	2	6085	80	2	1	2	4823	63	1	1	2
			4	6654	88	1	1	2	6159	81	1	1	2	4881	64	1	1	2
	700mA	76w	5S	7391	97	3	0	0	6841	90	3	0	0	5422	71	2	0	0
			5M	7327	96	3	0	1	6782	89	3	0	1	5375	71	3	0	1
			5W	6704	88	3	1	2	6206	82	3	1	2	4918	65	3	0	1
32 525			2	4930	88	2	1	2	4564	81	1	1	2	3617	65	1	1	2
			3	4966	89	1	1	2	4596	82	1	1	1	3643	65	1	1	1
	FOFA	56w	4	5026	90	1	1	2	4652	83	1	1	2	3687	66	1	1	1
	525mA		5S	5583	100	2	0	0	5168	92	2	0	0	4096	73	2	0	0
			5M	5535	99	2	0	1	5123	91	2	0	1	4060	73	2	0	1
			5W	5064	90	3	1	1	4688	84	3	1	1	3715	66	2	1	1
			2	3488	92	1	1	2	3229	85	1	1	1	2559	67	1	1	1
		00	3	3513	92	1	1	1	3252	86	1	1	1	2578	68	1	1	1
	250004		4	3556	94	1	1	1	3292	87	1	1	1	2609	69	0	1	1
	350mA	38w	5S	3950	104	2	0	0	3656	96	2	0	0	2898	76	1	0	0
			5M	3916	103	2	0	0	3625	95	2	0	0	2873	76	2	0	0
			5W	3583	94	3	1	1	3317	87	2	1	1	2628	69	2	1	1
			2	9864	90	2	2	3	9131	83	2	2	3	7236	66	2	1	2
				3	9935	90	2	1	2	9593	87	2	1	2	7288	66	2	1
	700mA	110w	4	10056	91	2	1	2	9309	85	1	1	2	7377	67	1	1	2
	7 OOHA	TTOW	5S	11169	102	3	0	0	10339	94	3	0	0	8193	74	3	0	0
			5 <b>M</b>	11073	101	4	1	2	10250	93	4	1	2	8123	74	3	1	2
			5W	10132	92	3	1	2	9379	85	3	1	2	9662	88	3	1	2
48		82w	2	7230	88	2	1	2	6692	82	2	1	2	5303	65	1	1	2
			3	7282	89	2	1	2	7031	86	2	1	2	5342	65	1	1	2
	525mA		4	7370	90	1	1	2	6823	83	1	1	2	5407	66	4	1	2
			5S	8186	100	3	0	0	7578	92	3	0	0	6005	73	3	0	0
			5M	8116	99	3	Ť	2	7512	92	3	1	2	5954	73	3	1	1
			5W	7426	91	3	1	1	6874	84	3	1	1	7081	86	2	1	1
	250m4	E 5.11	2	5211	95	2	1	2	4823	88	1	1	2	3822	69	1	1	1
			3	5248	95	1	1	2	5067	92	1	1	1	3850	70	1	1	1
			4	5312	97	1	7	2	4917	89	1	1	2	3897	71	1	1	1
	350mA	55w	5S	5900	107	2	0	0	5462	99	2	0	0	4328	79	2	0	0
			5M	5849	106	3	1	1	5415	98	3	1	1	4291	78	2	1	1
			5W	5352	97	3	1	1	4954	90	2	1	1	5104	93	2	1	0

Lumen values are from photometric tests performed in accordance with IESNA LM-79-08. Data is considered to be representative of the configurations shown. Actual performance may differ as a result of end-user environment, application and inherent performance tolerances of the electrical components.

AMBIENT TEMP.	0	25,000	50,000	*TM-21-11 60,000	100,000	CALCULATED L70 (hours)	
25°C / 77°F	1.00	0.98	0.96	0.96	0.94	>675,000	
40°C / 104°F	0.98	0.96	0.95	0.94	0.92	>556,000	

AMBIENT DATA					
TEMP		LUMEN MULT.			
0°C	32°F	1.02			
10°C	50°F	1.01			
20°C	68°F	1.00			
25°C	77°F	1.00			
30°C	86°F	1.00			
40°C	104°F	0.98			
50°C	122°F	0.98			







STUDIO SOUTHWEST ARCHITECTS, INC. 2101 Mountain Rd. NW, Albuquerque, NM 87104 505.843.9639 Fax 505.843.9683 Web Site: www.studioswarch.com Email: mail@studioswarch.com

© 2013, Studio Southwest Architects, Inc. Duplication or reproduction by any means without the express written consent of Studio Southwest Architects, Inc. is a violation of federal and International law. The information contained in this document is the intellectual property of Studio Southwest, Inc. and all rights thereto are Reserved. For exceptions refer to the Owner-Architect Agreement.

CONSULTANTS

Architect

## AIS MASTER PLAN PHASE

2400 12TH STREET ALBUQUERQUE NM 87104

> No Date Description

Revision Schedule DES DEV ISSUE: 1513 PROJECT NUMBER: FILE: 0000E-102.RVT DRAWN BY: Author CHECKED BY: Checker

SHEET TITLE

DATE:

FIXTURES - CUT SHEETS

03/30/15

E-102