

SAS MH#1153
 RIM: 5086.31
 CONDITION: GOOD
 FLOW: CONTINUOUS
 LID DIA: 24"
 MH MATERIAL: CONCRETE
 CENTER INV: 5077.46
 (ON STRUCTURE)
 OUTFLOW PIPE # 1
 PIPE 1: 8" PVC
 PIPE 1 INV: 5077.42
 PIPE 1 DIR: 3
 PIPE 2: 8" PVC
 PIPE 2 INV: 5077.51
 PIPE 2 DIR: 9

SASMH#1162
 RIM: 5094.35
 CONDITION: DID NOT OPEN
 WV5093.60


SASMH#1005
 RIM: 5077.47
 CONDITION: CANNOT OPEN

UTILITY KEYNOTES

1. CONNECT TO EXISTING WATER LINE
2. INSTALL NEW 1 1/2" DOMESTIC SERVICE WATER LINE
3. INSTALL NEW 6" FIRE PROTECTION LINE
4. INSTALL NEW POST INDICATOR VALVE
5. REMOVE EXISTING CAP
6. EXISTING 1" WATER METER
7. EXISTING 8" WATER LINE
8. INSTALL NEW HEATED ENCLOSURE FOR DOMESTIC REDUCED BACKFLOW PREVENTION
9. EXISTING 8" SANITARY SEWER LINE
10. INSTALL NEW 4" SANITARY SEWER LINE
11. CONNECT TO EXISTING SANITARY SEWER LINE. CONTRACTOR TO VERIFY EXACT LOCATION & DEPTH OF EXISTING SANITARY SEWER LINE.
12. INSTALL SANITARY SEWER CLEAN OUT.
13. INSTALL NEW FIRE HYDRANT.
14. INSTALL NEW 6" GATE VALVE.

UTILITY LEGEND

SAS	EXISTING SANITARY SEWER	SAS	PROPOSED SANITARY SEWER LINE
W	EXISTING WATER LINE	W	PROPOSED WATER LINE
□	EXISTING WATER METER	FIRE	PROPOSED FIRE WATER LINE
□	EXISTING CAP	□	PROPOSED CAP
X	EXISTING VALVE	X	PROPOSED PIV
○	EXISTING SANITARY SEWER MANHOLE	●	PROPOSED SAS CLEANOUT
		●	PROPOSED FIRE HYDRANT



NOT FOR
CONSTRUCTION

revision


by

date

rev



Mullen Heller
 Architecture P.C.
 924 Park Avenue SW
 Suite B
 Albuquerque 87102
 505 268 4144 [p]
 505 268 4244 [f]



job number 17-04
 drawn by AC
 project manager GSB
 date 06-07-2017

project title
Smiles for Kids Dental Office PHASE 2
 9211 Eagle Ranch Road, NW,
 Albuquerque, New Mexico 87114
 sheet title
Conceptual Site Utility Plan