DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 1004428 Ceja Vista Subdivision

AGENDA ITEM NO: 09

SUBJECT: Amended Preliminary Plat

ENGINEERING COMMENTS:



Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (PLNG)

FROM: Racquel M. Michel, P.E. Transportation Development 505-924-3991 or michel@cabg.gov DATE: March 21, 2018

Revised: 3/20/18

Agenda Item #9

DEVELOPMENT REVIEW BOARD

Code Enforcement Comments

AGENDA ITEM NO: ____9_____

DRB Project Number: <u>1004428</u>

Application Number: <u>18DRB-70007</u>

Project Name: _____

Request: Preliminary Plat

COMMENTS:

No objection.

(Comments may continue onto the next page)

<u>Disclaimer</u>: The comments provided are based upon the information received from the applicant/agent. If new or revised information is submitted, additional comments may be provided by Planning.

FROM:Benjamin McIntosh, Code Enforcement SupervisorDATE: 3/21/2018Planning Department924-3466 bmcintosh@cabq.gov

ACTION:

APPROVED ____; DENIED ____; DEFERRED ___; COMMENTS PROVIDED ___; WITHDRAWN ____

DELEGATED: (TRANS) (HYD) (WUA) (PRKS) (PLNG) (CE)

DEVELOPMENT REVIEW BOARD

Code Enforcement Comments

DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number:	1004428	Hearing Date:		3-21-2018	
Droioat	Ceja Vista, Tracts RR-3	Aganda Itan	o No.	0	
Project:	B, RR-3-C, RR-3-D, & RR-3-E		Agenda Item No:		9
Sketch Plat	Minor Preliminary / Final Plat	Amendment to Preliminary Plat		☐ Final Plat	
Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision		□ Bulk Land Variance	
□ SIA Extension	DPM Variance	□ Vacation of Easement	Public		tion of Public t of Way

ENGINEERING COMMENTS:

- Grading Plan and Drainage Report must be approved by Hydrology prior to Hydrology's signature of the Infrastructure List.
 - The Grading and Drainage plan needs to address the First Flush requirement.
 - This should include drainage swale and a culvert crossing at 98th within Dennis Chavez. Also needs to identify who is going to maintain the open ditch and culverts. Hydrology will need an approval letter from them stating that they are going to maintain the open ditch and culverts.
 - A revised Drainage Report will also need to be included in the Grading and Drainage submittal. Neither the original Drainage Report dated January 9, 2007 nor Supplemental Drainage Information dated April 2010 Units 1A through 1E were single family. Now Units 1A and 1B are multifamily which has a higher impervious area than the previous single family which was at 44%.
 - Also the original Drainage Report dated January 9, 2007 or Supplemental Drainage Information dated April 2010 did not take into account the First Flush requirement. Therefore the Drainage Report will have to be revised to include this requirement.
- Infrastructure List needs to be revised.
 - This should just read Unit 1 since all the infrastructure for Units 1A through 1C needs to be built at the same time.
 - According to the Supplemental Drainage Information dated April 2010, a drainage swale and a culvert crossing at 98th was to be built. So this needs to be added to the Infrastructure List.
- A recorded SIA is required prior to Hydrology's signature on the Final Plat.

RESOLUTION/COMMENTS:

Parks & Rec:

Water: Transportation: Planning:

APPROVED DENIED	DELEGATED TO: Delegated For:	□ TRANS	□ HYD	□ WUA		PLNG
	SIGNED: DI.L. DEFERRED TO			□ FINAL	_ PLAT	