



**Development Review Board (DRB)
Review Comments
Utility Development Section
Reviewer: Kristopher Cadena, P.E.
Phone: 505.289.3301**

DRB Project No: 1004428	Date: 05/09/18	Item No: #5
Zone Atlas Page: P-9	Legal Description: Tract(s) RR-3-A, RR-3-B, RR-3-C, RR-3-D, AND RR-3-E, CEJA VISTA Location: on DENNIS CHAVEZ BLVD SW south of 98 th ST SW and UNINCORPORATED AREAS	
Request For: 18DRB-70007 - AMENDMENT TO PRELIMINARY PLAT		

ABCWUA Comment:

Please provide written description of how the following comments were addressed with the next submittal.

- a. Spoke with engineer on 5/8/18 to change the beginning point for the 8" reuse water line in Unit 1 to Dennis Chavez Blvd. instead of "Existing 12" WL (2WR)". If this change is made, there are no other objections.

