

FM35001C0129H

FIRE ONE NOTES:

. BUILDING TYPE: II-B

2. SQUARE FEET: 9,900 SF

THE STREET.

3. THE TOTAL HEIGHT OF THE PROPOSED BUILDING SHALL NOT EXCEED 26'.

4. THE PROPOSED BUILDING SHALL BE FULLY SPRINKLED.

5. THE PARKING LOT SURFACE SHALL BE ASPHALT AND CAPABLE OF SUPPORTING AN IMPOSED LOAD OF A FIRE APPARATUS WEIGHING 75,000 LBS.

 THE MINIMUM DRIVE ISLE WIDTH SHALL 24'.
 BUILDINGS SHALL HAVE APPROVED ADDRESS NUMBERS OR BUILDING IDENTIFICATION PLACED

IN A POSITION PLAINLY LEGIBLE AND VISIBLE FROM

 ALL DRIVING SURFACES SHALL NOT EXCEED 10 PERCENT IN GRADE.

9. FIRE DEPARTMENT CONNECTION'S SHALL BE LOCATED WITHIN 100' OF A HYDRANT AND BE UNOBSTRUCTED FROM ANY OBJECT FOR A MINIMUM DISTANCE OF 3'.

10. POST INDICATOR VALVES SHALL BE PROVIDED PER NFPA 13.

11. A KNOX BOX SHALL BE PROVIDED AT THE ENTRANCE OF THE PROPOSED BUILDING AND AT GATE LOCATIONS.

+ provide scale *
-This can borred hop.



HYDRANT AND FIRE ACCESS
ALBUQUERQUE FIRE MARSHAL'S OFFICE
PLANS CHECKING DIVISION
SOFT 900 CONSTRUCTION TYPETER

GPM LOO NUMBER OF HYDRANTS L

APPROVED / DISAPPROVED

SIGNATURE / MAN NUMBER / DATE

LEGEND

PROPERTY BOUNDARY

EXISTING WATER LINE

PROPOSED WATER LINE

PROPOSED ROLLING DISTANCE


PROPOSED MARKED FIRE LANE

SCALE BOSQUE E

BREWING CAN & VENICE

ONE

FIRE



SHEET NUMBER:

1