

DEVELOPMENT REVIEW BOARD
TRANSPORTATION DEVELOPMENT

DRB Project Number: 1011533
Baldonado Property

AGENDA ITEM NO: 14

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. The proposed area is designed below current City of Albuquerque design criteria. A number of variances (width of pavement, lack of sidewalk) will be required for this request. Justification must be provided.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED ; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (PLNG)

FROM: Racquel M. Michel, P.E.
Transportation Development
505-924-3991 or rmichel@cabq.gov

DATE: March 14, 2018

DEVELOPMENT REVIEW BOARD

Code Enforcement Comments

AGENDA ITEM NO: 14

DRB Project Number: 1011533

Application Number: 18DRB-70058

Project Name: _____

Request: Sketch Plat

COMMENTS:

No comments.

(Comments may continue onto the next page)

Disclaimer: The comments provided are based upon the information received from the applicant/agent. If new or revised information is submitted, additional comments may be provided by Planning.

FROM: Benjamin McIntosh, Code Enforcement Supervisor DATE: 3/14/18
Planning Department
924-3466 bmcintosh@cabq.gov

ACTION:

APPROVED ___; DENIED ___; DEFERRED ___; COMMENTS PROVIDED ___; WITHDRAWN ___

DELEGATED: (TRANS) (HYD) (WUA) (PRKS) (PLNG) (CE)

DEVELOPMENT REVIEW BOARD

Code Enforcement Comments