

DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION
 Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 1011569 Hearing Date: 04-04-2018
 Project: Parkland Hills, Lots 1, 2 ,3 ,15, & 16, Block 25 Agenda Item No: 14

| | | | |
|---|---|---|--|
| <input checked="" type="checkbox"/> Sketch Plat | <input type="checkbox"/> Minor Preliminary / Final Plat | <input type="checkbox"/> Preliminary Plat | <input type="checkbox"/> Final Plat |
| <input type="checkbox"/> Temp Sidewalk Deferral | <input type="checkbox"/> Sidewalk Waiver/Variance | <input type="checkbox"/> Site Plan for Bldg. Permit <input type="checkbox"/> Site Plan for Subdivision | <input type="checkbox"/> Bulk Land Plat |
| <input type="checkbox"/> SIA Extension | <input type="checkbox"/> DPM Variance | <input type="checkbox"/> Vacation of Public Easement | <input type="checkbox"/> Vacation of Public Right of Way |

ENGINEERING COMMENTS:

- Cross Lot Drainage Easement note specifying the beneficiary and maintenance agreement must be added to the plat.
- For Information - Approved grading and drainage plan is required prior to Building Permit if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building , or 2,000 sf of proposed paving).

RESOLUTION/COMMENTS:

Parks & Rec:

Water:

Transportation:

Planning:

APPROVED
 DENIED

DELEGATED TO: TRANS HYD WUA PRKS PLNG
 Delegated For: _____
 SIGNED: I.L. SPSP SPBP FINAL PLAT
 DEFERRED TO _____