

2200 Sunport Blvd. SE

Administrative Amendment Request

Project #PR- 2018-001575

Transportation Development Comments:

Contact: Jennifer Restrepo, 505-924-3314, jrestrepo@cabq.gov

1. Please list the width and length for all proposed parking spaces. Some dimensions are not shown. (Proposed parking spaces are 9'x20', typical dimension notes added to plan.)
2. The ADA accessible parking sign must have the required language per 66-7-352.4C NMSA 1978 **"Violators Are Subject to a Fine and/or Towing."** Please show sign face details.(Concur, see detail 8, sheet C-501)
3. The ADA access aisles shall have the words **"NO PARKING"** in capital letters, each of which shall be at least one foot high and at least two inches wide, placed at the rear of the parking space so as to be close to where an adjacent vehicle's rear tire would be placed. (66-1-4.1.B NMSA 1978) (Concur, notes provided to detail 6, sheet C-501.)
4. Missing detail sheets C-501 – C-505 (Concur, will provide for review.)
5. Keynote 37 – Provide stop sign details (Concur, used COA standard details DWG 2600-601, 701 & 702, see detail 10, sheet C-501)
6. The minimum drive aisle dimensions are shown below (Project meets the Minimum Drive Aisle Width)

	Minimum Drive Aisle Width
Two Way Traffic	22'
Main Circulation Road	24'
Fire Lane	20'

7. List radii for all curves shown; for passenger vehicles. Radius for delivery trucks, fire trucks, etc. is 25 ft. or larger. (Radius provided on sheet C-121 & C-122 where fire trucks access in and out of the project site)
8. Provide pedestrian ramp details with truncated domes. (City of Albuquerque standard curb ramp with truncated domes, see Detail 1, sheet C-503.)
9. Will the highlighted area on the west end of the property (red) be a park? Please provide clarification. See image below.(Area for rest or dog relieve

area, material will be Engineered Wood Fiber, see Sheet LP-101 for Landscape Planting Plan.)

