



Project Name: Gateway Plaza Fremont CA
Plan Check Number:
In Response to: Plan Review Comments received on 01/03/2023
Date: 1/11/2023
Direct Contact: Anna Haefele ahaefele@blymyer.com (510)822-0353

	Comments from The City	Sheet #	EVgo Response and Actions
Comments	1.Please list the width and length for all existing parking spaces. Some dimensions are not shown.	G-101	All spaces dimensioned in G-101.
	2.Provide total parking calculations. List the number of parking spaces required by the IDO as well as the proposed number of parking spaces including bicycle and motorcycle parking.	G-001	Parking survey added to G-001
	3.The ADA accessible parking sign must have the required language per 66-7-352.4C NMSA 1978 "Violators Are Subject to a Fine and/or Towing." Please show sign face details.	G-104	Tow language added to detail 2 on sheet G-104