

SCOPE OF THIS SUBMITTAL, BUT ARE TO BE INCLUDED IN A NEW INFRASTRUCTURE

IMPROVEMENT AGREEMENT, MORE INFORMATION PROVIDED IN THE "UT" SHEETS

LIMIT OF CONSTRUCTION

PROPERTY LINE

16. EXISTING STORMWATER RETENTION POND

17. EXISTING WATER HARVESTING AND LANDSCAPED AREA



Kairos Power



1 REV1- DFT COMMENTS 2023-01-25

2 REV2- DFT COMMENTS 2023-03-01

OISN

 \triangleleft

REVIE

	REQUIRED:	PROVIDED:
TOTAL SPACES	238	193 + 30 NEW + 48 HOV** = 271
HOV SPACES	0	12
ACCESSIBLE PARKING	8 TOTAL / 2 VAN	12 TOTAL / 6 VAN
MOTORCYCLE SPACES	5	12
DIVE DADIVINO	0.4	0.4 (0.NE)AA

8.5

ADA ACCESS AISLE 8'


18'


18'


N/A

** 12 SPACES X 4 CARPOOL CREDIT PER IDO SECTION 5-5(C)(6)(B) = 48 SPACES TOWARD THE REQUIRED OFF-STREET PARKING REQUIREMENT

PROJECT NO.: 8000-22 DRAWN BY: DATE: MARCH 2, 2023







EXITING REQUIREMENTS (TABLE 1005.1)

NO ENCLOSURE WALL ON SOUTH SIDE (120 L.F.)

EGRESS WIDTH REQUIRED:

13013 glenwood hills ct. ne albuquerque nm 87111 (ph) 505 514 1364



REVISIONS

EXISTING FACILITIES IN OFFICE WITHIN 500'

2A-10BC FIRE EXTINGUISHER, WALL MOUNTED (1 PER 3,000 SF, 75'

ACCESSORY STORAGE BUILDING, NO ENCLOSURE WALL ON SOUTH SIDE (120 L.F.)

NEW - 12 OCCUPANTS (6 FEMALE, 6 MALE) 1 WC AND 1 LAVATORY REQUIRED

REQUIRED PLUMBING FIXTURES

TRAVEL DISTANCE MAX.) - 2-REQUIRED

EXECUTIVE SUMMERY

CODE DATA

PUBLISHED BY ICC

NO CONDITIONED SPACE PROVIDED

APPLICABLE BUILDING CODES

2015 NM EXISTING BLDG CODE

2017 NM ELECTRICAL CODE

OCCUPANCY CLASSIFICATION:

S-2 LOW HAZARD STORAGE

CONSTRUCTION AREA DATA BUILDING AREA: 6,000 SF

CONSTRUCTION TYPE:

OCCUPANT LOAD

FIRE EXTINGUISHER

2012 NM ELECTRICAL SAFETY CODE

II-B 1-STORY (NON-SPRINKLED)

6.000/500 OLF = 12 OCCUPANTS

2018 NM ENERGY CONSERVATION CODE

2021 NM MECH. CODE INCL APPENDIXES A,B,C,D

2021 NM PLUMBING CODE INCL APPENDIXES A,B,D,E,F,I,L

2015 NM COMMERCIAL BLDG CODE INCL. APPENDIXES E,I

2015 INTERNATIONAL CODE COUNCIL PERFORAMNCE CODE


FOR BLDGS & FACILITIES INCL ALL APPENDIX CHAPTERS

GENERAL NOTE 907.2.13.1.2 DUCT SMOKE DETECTION. DUCT SMOKE DETECTORS COMPLYING WITH SECTION 907.4.1 SHALL BE LOCATED AS FOLLOWS: 1. IN THE MAIN RETURN AIR AND EXHAUST AIR PLENUM OF EACH AIR-CONDITIONING SYSTEM HAVING A CAPACITY GREATER THAN 2,000 CUBIC FEET PER MINUTE (CFM) (0.94 M3/S). SUCH DETECTORS SHALL BE LOCATED IN A SERVICEABLE AREA DOWNSTREAM OF THE LAST DUCT INLET. 2. AT EACH CONNECTION TO A VERTICAL DUCT OR RISER SERVING TWO OR MORE STORIES FROM A RETURN AIR DUCT OR PLENUM OF AN AIR-CONDITIONING SYSTEM. IN GROUP R-1 AND R-2 OCCUPANCIES, A SMOKE DETECTOR IS ALLOWED TO BE USED IN EACH RETURN AIR RISER CARRYING NOT MORE THAN 5,000 CFM (2.4 M3/S) AND SERVING NOT MORE THAN 10 AIR-INLET OPENINGS.

GENERAL NOTES FOR FIRE PROTECTION SYSTEMS

- FIRE SPRINKLER SHOP DRAWINGS SHALL BE SUBMITTED TO THE ALBUQUERQUE FIRE MARSHAL'S OFFICE FOR REVIEW AND APPROVAL OF ANY INSTALLATION OR MODIFICATION TO TEH FIRE SPRINKLER SYSTEM, FIRE ALARM SYSTEM, KITCHEN SUPPRESSION SYSTEM OR ANY OTHER FIRE RELATED SYSTEM
- THE FIRE SPRINKLER SYSTEM WILL BE SUPERVISED WHEN REQUIRED BY THE 2015 INTERNATIONAL FIRE CODE

PARKING DATA EXISTING BUILDING: •• NO CHANGE TO EXISTING PARKING NEW BUILDING STORAGE (ACCESSORY USE)6,000 SF - NO REQUIREMENT



14

Kairos row 5201 Hawking Albuquerque,