DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 001346 AGENDA ITEM NO: 4
Whataburger on San Pedro and Alameda

SUBJECT: Site Plan

ENGINEERING COMMENTS:

1. In addition to information provided, indicate turnover time for the restaurant.

2. Ensure a sufficient 4-foot ADA pathway around the back of any perpendicular ramp for the wheelchair to maneuver. (This can be called out on the detail provided.)

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: May 4, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)