

# Pres Center on Louisiana

---

## Administrative Amendment Request

Project #PR 2018-001579      SI-

Transportation Development Comments:

- Platting is required prior to building permit.
- Fire Marshall Approval and Solid Waste Approval is required prior to Transportation's approval.
- There is a concrete joint detail for the northern wall but not a wall cross-section provided for the number referenced on the site plan. **The cross section is A1/AS101**
- Adjust sight distance triangle locations to match standards in DPM. The mini sight triangle is shown behind the sidewalk. Adjust landscaping if needed. **They have been adjusted.**
- Label "MC" in back of motorcycle spaces and "Compact" in back of compact spaces. **Labels have been added.**

Contact:            Jeanne Wolfenbarger            924-3991, [jwolfenbarger@cabq.gov](mailto:jwolfenbarger@cabq.gov)