DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2019-001774 Hearing Date: **05-25-2022**

Project: Andretti Racing Agenda Item No: **5**

| | | | |
|---|---|---|---|
| ☒ Sketch Plat | ☐ Minor Preliminary / Final Plat | ☐ Preliminary Plat | ☐ Final Plat |
| ☐ Temp Sidewalk Deferral | ☐ Sidewalk Waiver/Variance | ☐ Site Plan for Bldg. Permit<br>☐ Site Plan for Subdivision | ☐ Bulk Land Plat |
| ☐ Modifications to IL | ☐ DPM Variance | ☐ Vacation of Public Easement | ☐ Vacation of Public Right of Way |

**ENGINEERING COMMENTS:**

- Hydrology needs to approve the Grading & Drainage Plan.
- Calculations for the existing/proposed retention pond will need to adjust for the increased impervious area of this development. The proposed site plan may not work as shown.

**RESOLUTION/COMMENTS:**

Code Enforcement:

Water:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____