DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2019-001948 Hearing Date: **06-08-2022**

Project: Tr A, Prima Entrada Agenda Item No: **5**

☐ Sketch Plat	☒ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☒ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has an approved Revised Grading & Drainage Plan (J09D020A) with Engineer's stamp date: 08/24/20.
- Hydrology has no objection to the R.O.W. Vacation.
- **Prior to Hydrology's approval of the Vacation of Public Drainage Easement and Plat**
    - The site must be graded and the pads certified (Engineer's Certification).

- For Information. Per conversation between the City Engineer and the AMAFCA Executive Engineer, AMAFCA has established the legal right to construct the pipe across the DCLP Trust Property by Court Order. And AMAFCA accepts full responsibility of the pipe capacity and maintenance.

RESOLUTION/COMMENTS:

Code:

Water:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____