DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 001985 AGENDA ITEM NO: 11
812 Arno

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. The alleyway shall be widened to required 20 feet or justification shall be provided to maintain it at 16 feet. If using the narrowed width, a DRB Determination will need to be made.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: June 8, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)