DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**
Ernest Armijo PE, Principal Engineer 924-3986 earmijo@cabq.gov

DRB Project Number: 2018-001996, 1010401 Hearing Date: **5-25-2022**

Project: Durango Unit 2 Agenda Item No: **3**

☒ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Amend Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has approved rough grading plan with Engineer's stamp date of 7/31/21 (C09D012), but in reviewing the proposed plat the lot layout does not match that approved grading plan. Either the lot layout needs to be changed to match the approved plan or the grading plan needs to be changed to match the new layout

RESOLUTION/COMMENTS:

Water:

Code:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____