DEVELOPMENT HEARING OFFICER

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2019-002089 AGENDA ITEM NO: 6
239-243 Anna Maria Pl.

SUBJECT: Preliminary/Final Plat

ENGINEERING COMMENTS:

1. Please provide a diagram showing existing sidewalk width along with property line and roadway width. Anna Maria is a local road and 5' sidewalks with a 4-6' landscape buffer are required. If you cannot meet the requirements you may request a determination with a justification letter.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Ernest Armijo, P.E.
Transportation Development
505-924-3991 or earmijo@cabq.gov

DATE: November 8, 2023

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)