DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION

Dana Peterson PE., 924-3695, dpeterson@cabq.gov

DRB Project Number:	2019-002184	Hearing	Date:	12-18-2019	
Project:	Guardian Storage Juar Osuna	n Tabo &	Agenda Iter	n No:	1
☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary I	Plat	☐ Final	Plat
☐ Temp Sidewalk Deferral	□ Sidewalk Waiver/Variance	☑ Site Plan		☐ Bulk	Land Plat
☐ 2 YEAR SIA Extension	☐ DPM Variance	☐ Vacation of I Easement	Public		ition of Public t of Way
ENGINEERING COMM	MENTS:				
 An approved conceptual grading and drainage plan is required. The pipe penetration into Bear Canyon Arroyo needs to be on the Infrastructure List 					
RESOLUTION/COMM	ENTS:				
Code:					
Parks & Rec:					
Water:					
Transportation:					
Planning:					
□ DENIED [DELEGATED TO: □ TRAI Delegated For: SIGNED: □ I.L. □ SPSD		□ WUA I	□ PRKS PLAT	□ PLNG
1	DEFERRED TO				