DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE, Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2019-002277 Hearing Date: **2-9-2022**

Project: Cantata at the Trails Unit 2, Tract A Agenda Item No: **9**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☒ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has an approved Conceptual Grading and Drainage Plan (C09D014) with Engineer's stamp date: 8/16/19 and a Rough Grading Plan with Engineer's stamp date: 5/31/21
- No objection to the Site Plan
- Please note when the final Grading and Drainage Plan is submitted prior to Building Permit or Work Order, all procedures and calculations must follow the current DPM chapter 6 as the current Conceptual Plan was done using the older DPM chapter 22.

RESOLUTION/COMMENTS:

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____