DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2019-002607 Hearing Date: **1-27-2021**

Project: Lot8B, Alvarado Gardens U1 Agenda Item No: **15**

☐ Sketch Plat	☒ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☒ Vacation of Private Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- No Objection to Plat or Vacation
- For Information. If future development exceeds 1000sf of building, 10000sf of paving, 500cy of grading or 1ac of grading, an approved grading and drainage plan may be required. Flat valley grading criteria will be required and must include a solid perimeter wall to restrict cross lot drainage

RESOLUTION/COMMENTS:

Code:

Water:

Transportation:

Planning:

Parks & Rec.:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____