DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2019-002610 Hearing Date: **01-27-2021**

Project: Lot 1, Campbell Farm South Agenda Item No: **8**

☐ Sketch Plat	☒ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☒ Vacation of Public Easement	☒ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has no objection to the Vacation of R.O.W. (ditch).
- Hydrology has no objection to the Vacation of R.O.W. (road).
- Hydrology has no objection to the Vacation of easement.
- Hydrology has no objection to the platting action.

- Comment - An approved Grading and Drainage Plan is required prior to Building Permit if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving). Also the Grading and Drainage Plan will have to follow the DPM Article 6-5 Valley Drainage Criteria.

RESOLUTION/COMMENTS:

Code Enforcement:

Water:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____