DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE, Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2019-002651 Hearing Date: **6-15-2022**

Project: 1501 Aircraft Agenda Item No: **7**

☐ Sketch Plat	☒ Minor Preliminary / Final Plat	☐ Preliminary Plat Ext	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- A cross lot drainage easement naming beneficiaries and maintenance responsibilities will need to be added to the plat.
- At time of development an approved Grading and Drainage Plan will be required prior to Site plan or Building permit if any of the following conditions are met: 500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving.

RESOLUTION/COMMENTS:

Water:

Code:

Parks and Rec.:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____