DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 005482 AGENDA ITEM NO: 18
Washington Street and Ellison

SUBJECT: Plat, Infrastructure List

ENGINEERING COMMENTS:

1. 5-foot sidewalk shall be built on Washington Street along front of property. Include additional access as needed for easements; these shall be ADA-compatible.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: March 30, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)