DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE, Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2019-002738 Hearing Date: **2-24-2021**

Project: 5900 Menaul NE Agenda Item No: **16**

| | | | |
|---|---|---|---|
| ☐ Sketch Plat | ☒ Minor Preliminary / Final Plat | ☐ Preliminary Plat | ☐ Final Plat |
| ☐ Temp Sidewalk Deferral | ☐ Sidewalk Waiver/Variance | ☐ Site Plan for Bldg. Permit<br>☐ Site Plan for Subdivision | ☐ Bulk Land Plat |
| ☐ IIA Extension | ☐ DPM Variance | ☐ Vacation of Public Easement | ☐ Vacation of Public Right of Way |

**ENGINEERING COMMENTS:**

- No objection
- Note: An approved grading and drainage plan will be required for building permit if any of the following conditions are met: 500 cy of grading, 1000 sf of structure, 10000 sf of paving.

**RESOLUTION/COMMENTS:**

Code:

Water:

Transportation:

Planning:

Parks & Rec:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____