

DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION
 Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2019-002905 Hearing Date: 01-15-2020
 Project: Lot 2-A-2-1 & 2-A-2-2, Block 2, Sunport Park Agenda Item No: 11

<input checked="" type="checkbox"/> Sketch Plat	<input type="checkbox"/> Minor Preliminary / Final Plat	<input type="checkbox"/> Preliminary Plat	<input type="checkbox"/> Final Plat
<input type="checkbox"/> Temp Sidewalk Deferral	<input type="checkbox"/> Sidewalk Waiver/Variance	<input type="checkbox"/> Site Plan for Bldg. Permit <input type="checkbox"/> Site Plan for Subdivision	<input type="checkbox"/> Bulk Land Plat
<input type="checkbox"/> SIA Extension	<input type="checkbox"/> DPM Variance	<input type="checkbox"/> Vacation of Public Easement	<input type="checkbox"/> Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has no objections to the Preliminary Plat.
- Approved Grading and Drainage Plan is required prior to Building Permit if one of these conditions is met. (500 cy of grading, 1,000 sf of proposed building, or 10,000 sf of proposed paving).
- Comment – Lot 2-A-2-1 according to the Master Drainage Plan has an allowable discharge rate of 3.4 CFS/AC.
- Comment – Lot 2-A-2-2 according to the Master Drainage Plan has an allowable discharge rate of 4.0 CFS/AC.

RESOLUTION/COMMENTS:

Code Enforcement:

Water:

Transportation:

Planning:

APPROVED
 DENIED

DELEGATED TO: TRANS HYD WUA PRKS PLNG
 Delegated For: _____
 SIGNED: I.L. SPSP SPBP FINAL PLAT
 DEFERRED TO _____