DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE, Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2019-002976 Hearing Date: **4-14-2021**

Project: 17400 Hilldale Rd. NE Agenda Item No: **11**

☐ Sketch Plat	☒ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☒ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ IIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- No objection to the waiver or the plat.
- Note: An approved grading and drainage plan will be required for any development on this site if any of the following conditions are met: 500 cy of grading, 1000 sf of proposed structure, 10,000 sf of proposed paving.

RESOLUTION/COMMENTS:

Parks & Rec:

Water:

Transportation:

Planning:

Code:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____