

DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION
 Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2019-003062 Hearing Date: 01-08-2020
 Project: Lots A-3-A-1 & A-3-A-2, Thunderbird Partnership Agenda Item No: 18

<input checked="" type="checkbox"/> Sketch Plat	<input type="checkbox"/> Minor Preliminary / Final Plat	<input type="checkbox"/> Preliminary Plat	<input type="checkbox"/> Final Plat
<input type="checkbox"/> Temp Sidewalk Deferral	<input type="checkbox"/> Sidewalk Waiver/Variance	<input type="checkbox"/> Site Plan for Bldg. Permit <input type="checkbox"/> Site Plan for Subdivision	<input type="checkbox"/> Bulk Land Plat
<input type="checkbox"/> SIA Extension	<input type="checkbox"/> DPM Variance	<input type="checkbox"/> Vacation of Public Easement	<input type="checkbox"/> Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology will need an approved Grading and Drainage Plan prior to approval of Preliminary Plat or Site Plan for Subdivision.
- A Cross Lot Drainage Easement note specifying the beneficiary and maintenance agreement may be needed depending on the approved G&D.

RESOLUTION/COMMENTS:

Code Enforcement:

Water:

Transportation:

Planning:

APPROVED
 DENIED

DELEGATED TO: TRANS HYD WUA PRKS PLNG
 Delegated For: _____
 SIGNED: I.L. SPSP SPBP FINAL PLAT
 DEFERRED TO _____