DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, PE, Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2020-003441 Hearing Date: **2-3-2021**

Project: Lot 7 Santo Domingo St Agenda Item No: **4**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☒ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- A diagram showing existing drainage patterns is required to determine if the proposed vacation carries drainage that needs to be maintained.
- On the plat show actual dimensions of the proposed vacation.
- At replat a Grading and Drainage plan will be required

RESOLUTION/COMMENTS:

Code Enforcement:

Water:

Transportation:

Planning:

Parks:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____