DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2018-003657 AGENDA ITEM NO: 10

SUBJECT: Plat

ENGINEERING COMMENTS:

1. A minimum 4-foot sidewalk is required around the fire hydrant at this location.
2. Demonstrate that fenceline is not encroaching into right-of-way. If it is within the right-of-way, it will either need to be removed or a revocable permit shall be required.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: January 6, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)