DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 004215 AGENDA ITEM NO: 14
6201 Montgomery Blvd.

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Include Traffic Circulation Layouts as part of the submittal to show how the buildings correlate with the access easement that is proposed.

2. List sidewalk width along San Pedro and Montgomery to verify that it meets the minimum 6-foot width requirement.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: March 2, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)