DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Renée Brissette, PE, Senior Engineer | 505-924-3995 rbrissette@cabq.gov

DRB Project Number: 2020-004284 Hearing Date: **09-28-2022**

Project: Tracts 1-4, Rio Grande Crossing West Agenda Item No: **6**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☒ Admend IL	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Hydrology has an approved Master Drainage Report and Conceptual Grading & Drainage Plan (H13D109) with Engineer's Stamp Date: 11/10/20.
- There is also an approved DRC plans (759483) with Engineer's Stamp Date 3/22/22.
- Both of these approvals were based on the 42 ft F-F access roads.
- Hydrology cannot approve the Amendment to the Infrastructure List to change the access road from 42 ft F-F to 24 ft F-F.

RESOLUTION/COMMENTS:

Water:

Code Enforcement:

Parks:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____