DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2020-004370 AGENDA ITEM NO: 21
619 and 623 14th Street NW

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Label existing sidewalk width on 14th Street. Provide plan showing this sidewalk with relationship to property line and provide a distance from the curb to the property line.

2. A minimum 20-foot wide right-of-way is required for the alleyway.

*Please remember to email me directly with an electronic copy of all supplemental submittal documents.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: March 2, 2022

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)