DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 004433 AGENDA ITEM NO: 2
828 Victoria Drive

SUBJECT: Plat

ENGINEERING COMMENTS:

1. It is preferred to have right-of-way dedicated in lieu of having the roadway easement.
2. Label sidewalk widths along frontage of property. 5-foot minimum sidewalk is required according to roadway classification.
3. Remove the word “Sketch Plat”.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: January 20, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)