DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2020-004433 Hearing Date: **1-20-2021**

Project: 8028 & 8032 Victoria Dr. Agenda Item No: **2**

☐ Sketch Plat	☒ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Deferral from Infrastructure List	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☐ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- No objection
- Note: An approved grading and drainage plan will be required prior to building permit if any of the following conditions is met: 500 cy of grading, 1,000 sf of building, or 10,000 sf of paving

RESOLUTION/COMMENTS:

Code Enforcement:

Water:

Transportation:

Planning:

Parks:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____