

DEVELOPMENT REVIEW BOARD - HYDROLOGY SECTION
 Ernest Armijo P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2020-004433 Hearing Date: 2-3-2021
 Project: 8028 & 8032 Victoria Dr. Agenda Item No: 15 & 16

<input type="checkbox"/> Sketch Plat	<input checked="" type="checkbox"/> Minor Preliminary / Final Plat	<input type="checkbox"/> Preliminary Plat	<input type="checkbox"/> Final Plat
<input type="checkbox"/> Temp Sidewalk Deferral	<input checked="" type="checkbox"/> Sidewalk Waiver	<input type="checkbox"/> Site Plan for Bldg. Permit <input type="checkbox"/> Site Plan for Subdivision	<input type="checkbox"/> Bulk Land Plat
<input type="checkbox"/> SIA Extension	<input type="checkbox"/> DPM Variance	<input type="checkbox"/> Vacation of Public Easement	<input type="checkbox"/> Vacation of Public Right of Way

ENGINEERING COMMENTS:

- No objection
- Note: An approved grading and drainage plan will be required prior to building permit if any of the following conditions is met: 500 cy of grading, 1,000 sf of building, or 10,000 sf of paving

RESOLUTION/COMMENTS:

Code Enforcement:

Water:

Transportation:

Planning:

Parks:

APPROVED
 DENIED

DELEGATED TO: TRANS HYD WUA PRKS PLNG
 Delegated For: _____
 SIGNED: I.L. SPSD SPBP FINAL PLAT
 DEFERRED TO _____