Albuquerque Bernalillo County
Water Utility Authority

P.O. Box 1293
Albuquerque, NM 87103

Development Review Board (DRB)
Review Comments
Utility Development Section
Reviewer: Blaine Carter, P.E.
Phone: 505.415.9188

DRB Project No:	Date:	Item No:
PR-2020-004548	04/07/21	#8
Zone Atlas Page: D-10	Legal Description: Lot(s) 27 & 28 BLOCK 6 UNIT 22, VOLCANO CLIFFS SUBDIVISION Location: 6201 & 6205 PAPAGAYO RD between CAMINO ALDERETE and PETROGLYPHS/NATIONAL MONUMENT	
Request For: SD-2021-00052 – PRELIMINARY/FINAL PLAT VA-2021-00071 – SIDEWALK WAIVER		

ABCWUA Comment:

Please provide written description of how the following comments were addressed with the next submittal.

1. **SD-2021-00052 – PRELIMINARY/FINAL PLAT**
   a. No objection.
   b. Information Only: The sewer line in front of this property is a 2" force main. A pumped connection to this line will be required at the time of development.

2. **VA-2021-00071 – SIDEWALK WAIVER**
    a. No objection