



**PNM Comments
Development Review Board
Public Meeting to be Held on January 13, 2021**

**PNM comments for Approval for DRB # PR-2020-004604 (SI-2020-001467) Site Plan
(Holly Ave NE between Ventura St NE and Desert Shadow Way NE)**

1. It is the applicant's obligation to determine if existing utility easements or rights-of-way are located on or adjacent to the property and to abide by any conditions or terms of those easements.
2. As the development moves forward, the applicant needs to contact the PNM New Service Delivery Department to coordinate electric service regarding this project. Please submit a service application at www.pnm.com/erequest for PNM to review.
3. Ground-mounted equipment screening will be designed to allow for access to utility facilities. All screening and vegetation surrounding ground-mounted transformers and utility pads are to allow 10 feet of clearance in front of the equipment door and 5-6 feet of clearance on the remaining three sides for safe operation, maintenance and repair purposes. Refer to the PNM Electric Service Guide at www.pnm.com for specifications.
4. There is an existing overhead distribution line immediately adjacent on the project's east side along Ventura St NE. If existing electric lines need to be moved or undergrounded, then that is at the developer's expense. Please contact PNM at www.pnm.com/erequest for PNM to review.
5. Safety clearances for construction and final design of the building(s) near the distribution line along Ventura St NE shall show compliance with NESC requirements prior to any approvals. Refer to the PNM Electric Service Guide at www.pnm.com for specifications.