DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2020-004888 Hearing Date: **2-10-21**

Project: Panorama Addition Agenda Item No: **8**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☒ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- Please coordinate with Real Property for purchase of this ROW.
- Please provide a diagram showing existing drainage patterns in the ROW proposed to be vacated and the lots to be consolidated. A drainage easement may be required.
- An approved Grading and Drainage plan will be required at platting.

RESOLUTION/COMMENTS:

Parks & Rec.:

Code:

Water:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____