DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 004748 AGENDA ITEM NO: 3
400 Marquette

SUBJECT: Vacation

ENGINEERING COMMENTS:

1. The Transportation Department has no objection to the vacation of the alleyway off of 5th Street.

   Prior to platting sign-off:

2. The curve for right-of-way dedication at the northwest corner to include curb ramp and required sidewalk width appears to be adequate.

3. Verify that a minimum 4-foot wide sidewalk can be provided around obstacles such as light poles. Provide measurements to make sure that this minimum clearance is met. Right-of-way dedication should take this into account.

4. Overall sidewalk width shall be 10 feet in downtown areas. Check on right-of-way dedication requirements for 5th Street.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: March 17, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)