DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 2018-004457 AGENDA ITEM NO: 2
Quivera Road

SUBJECT: Plat, Vacation

ENGINEERING COMMENTS:

1. Show 5-foot sidewalk on the roadway sections provided.
2. Curves on either end of the vacation at Gila and Retablo shall be adjusted on the plat.
3. Provide the Fire 1 Plan.
4. On the infrastructure list, show 5-foot sidewalk for all roadways to match new DPM requirements.

*Please remember to send an electronic copy of all supplemental submittal documents.

Disclaimer: The comments provided are based upon the information received from the applicant. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: January 6, 2021

---

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)