DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 004812 AGENDA ITEM NO: 2
Alleyway, 5th and 6th Street

SUBJECT: Plat, Vacation

ENGINEERING COMMENTS:

1. Written approval from neighbors adjacent to the alleyway portion that is proposed for vacation is needed.

2. Prior to platting action, label existing sidewalk width prior to platting action to determine adequacy.

3. Any enroachments in right-of-way (fences/walls) shall be removed or a revocable permit shall be needed.

4. Because the alleyway is over 150 feet long, seek Solid Waste Approval prior to approval of vacation.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: February 3, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)