DEVELOPMENT REVIEW BOARD - **HYDROLOGY SECTION**

Ernest Armijo, P.E., Principal Engineer | 505-924-3986 earmijo@cabq.gov

DRB Project Number: 2020-004888 Hearing Date: **1-27-21**

Project: Panorama Addition Agenda Item No: **7**

☐ Sketch Plat	☐ Minor Preliminary / Final Plat	☐ Preliminary Plat	☐ Final Plat
☐ Temp Sidewalk Deferral	☐ Sidewalk Waiver/Variance	☐ Site Plan for Bldg. Permit ☐ Site Plan for Subdivision	☐ Bulk Land Plat
☐ SIA Extension	☐ DPM Variance	☐ Vacation of Public Easement	☒ Vacation of Public Right of Way

ENGINEERING COMMENTS:

- If this ROW is intended to be added to lots 8, 9 and 10, please coordinate with Real Property as this ROW must be purchased.
- Please provide a diagram showing existing drainage patterns in the ROW proposed to be vacated and the lots to be consolidated.
- An approved Grading and Drainage plan may be required if the existing ROW carries drainage flows.

RESOLUTION/COMMENTS:

Parks & Rec.:

Code:

Water:

Transportation:

Planning:

☐ APPROVED
☐ DENIED

DELEGATED TO: ☐ TRANS ☐ HYD ☐ WUA ☐ PRKS ☐ PLNG
Delegated For: _____
SIGNED: ☐ I.L. ☐ SPSD ☐ SPBP ☐ FINAL PLAT
DEFERRED TO _____