DEVELOPMENT REVIEW BOARD

TRANSPORTATION DEVELOPMENT

DRB Project Number: 004966 AGENDA ITEM NO: 6
1419 Los Tomases

SUBJECT: Sketch Plat

ENGINEERING COMMENTS:

1. Label the existing right-of-way width and the existing sidewalk width on Los Tomases. A minimum 5-foot sidewalk is required along the frontage. Double-check right-of-way dedication based on these requirements.

. If new or revised information is submitted, additional comments may be provided by Transportation Development.

FROM: Jeanne Wolfenbarger, P.E.
Transportation Development
505-924-3991 or jwolfenbarger@cabq.gov

DATE: August 28, 2021

ACTION:

APPROVED __; DENIED __; DEFERRED __; COMMENTS PROVIDED __; WITHDRAWN __

DELEGATED: _____ TO: (TRANS) (HYD) (WUA) (PRKS) (CE) (PLNG)