

March 5<sup>th</sup>, 2021

Jeanne Wolfenbarger  
Email: [jwolfenbarger@cabq.gov](mailto:jwolfenbarger@cabq.gov)  
Phone: 924-3991

**Re: Wal-Mart at 4700 Cutler, Administrative Amendment Request, Project #PR-2021-005016**

Dear Jeanne,

Please find responses below in bold addressing the Transportation Development Comments received February 18, 2021.

1. For centerline striping, ratio of the gap to the stripe should be 3:1.

**Response: Centerline is a 4" wide yellow stipe 6' long with 18' gaps, per Schedule Note Z on sheet 6020 – SECP-1 Demolition & Site Construction Plan, providing a gap to stripe ratio of 3:1.**

2. Provide "Yield to Pedestrian" signage on either side of the main crosswalk entrance per MUTCD requirements.

**Response: "Stop Here for Pedestrians" signage (R1-5b) is shown on either side of crosswalks, per Schedule Note R.**

3. In the package, I did not see any details for signage and striping or a plan for parking spaces that involve pick-up only, similar to the other Wal-Mart packages. Please make sure to provide all plans.

**Response: Requested sheets were issued with Addendum #2 on 2-25-2021 and will be included as necessary with any subsequent submittals.**

4. Be sure to cross out keyed notes that are not used for this submittal. For any detail sheets provided, delete any signage that is not being used.

**Response: Unused key notes crossed out as requested. Detail standards are at Walmart's request for all projects to ensure consistency throughout all Walmart locations and have been left for consistency purposes. Please let us know if this is still of concern.**

Sincerely,



Ryan James, PE  
Sr. Civil Project Manager  
Galloway & Company, Inc.

